

Application No. OH0027481

Modification Issue Date: September 9, 2014

Modification Effective Date: December 1, 2014

Expiration Date: July 31, 2017

Ohio Environmental Protection Agency
Authorization to Discharge Under the
National Pollutant Discharge Elimination System

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as the "Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code Section 6111),

City of Springfield

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA," to discharge from the City of Springfield wastewater treatment works located at 965 Dayton Road, Springfield, Ohio, Clark County and authorized combined sewer overflows and discharging to the Mad River, Buck Creek, Mill Run and unnamed ditches in accordance with the conditions specified in Parts I, II and III of this permit.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

Craig W. Butler
Director

Total Pages: 63

Part I, A. - INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit modification and lasting until 7 months from the effective date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 1PE00007001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 - Interim

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months		
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Maximum Indicating Thermometer	All
00300 - Dissolved Oxygen - mg/l	-	5.0	-	-	-	-	-	1/Day	Continuous	All
00530 - Total Suspended Solids - mg/l	-	-	45	30	-	4260	2840	4/Week	24hr Composite	Winter
00530 - Total Suspended Solids - mg/l	-	-	30	20	-	2840	1900	4/Week	24hr Composite	Summer
00552 - Oil and Grease, Hexane Extr Method - mg/l	10	-	-	-	-	-	-	1 / 2 Weeks	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	4.5	3.0	-	426	284	5/Week	24hr Composite	Summer
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	15	10	-	1420	947	5/Week	24hr Composite	Winter
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1 / 2 Weeks	24hr Composite	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00719 - Cyanide, Free - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01079 - Silver, Total Recoverable - ug/l	-	-	-	-	-	-	-	1 / 2 Weeks	24hr Composite	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units		Loading* kg/day					Measuring Frequency	Sampling Type	Monitoring Months
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	1/Day	Grab	Summer
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50060 - Chlorine, Total Residual - mg/l	0.038	-	-	-	-	-	-	1/Day	Multiple Grab	Summer
50092 - Mercury, Total (Low Level) - ng/l	1700	-	-	12	0.161	-	0.00114	1/Month	Grab	All
61425 - Acute Toxicity, Ceriodaphnia dubia - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61426 - Chronic Toxicity, Ceriodaphnia dubia - TUC	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61427 - Acute Toxicity, Pimephales promelas - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61428 - Chronic Toxicity, Pimephales promelas - TUC	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Continuous	All
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Continuous	All
70300 - Residue, Total Filterable - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
80082 - CBOD 5 day - mg/l	-	-	23	15	-	2180	1420	4/Week	24hr Composite	Summer
80082 - CBOD 5 day - mg/l	-	-	33	22	-	3130	2090	4/Week	24hr Composite	Winter

NOTES for Station Number 1PE00007001:

* Effluent loadings based on average design flow of 25 MGD.

- Flow rates may be monitored at the effluent of the primary treatment system and reported at final outfall station 1PE00007001.

- Total residual chlorine - See Part II, Item P.

- Nickel, zinc, cadmium, lead, total chromium, chromium, copper, and silver - See Part II, Item T.

- Dissolved hexavalent chromium - See Part II, Item U.

- Mercury - See Part II, Items U and AA.

- Free cyanide - See Part II, Items U and Z.

- Whole effluent toxicity - See Part II, Item DD.

- Silver - See Part I.C, Schedule of Compliance, Item A.

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

2. During the period beginning 7 months from the effective date of this permit modification and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 1PE00007001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months		
Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly	
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Maximum Indicating Thermometer	All
00300 - Dissolved Oxygen - mg/l	-	5.0	-	-	-	-	-	1/Day	Continuous	All
00530 - Total Suspended Solids - mg/l	-	-	45	30	-	4260	2840	4/Week	24hr Composite	Winter
00530 - Total Suspended Solids - mg/l	-	-	30	20	-	2840	1900	4/Week	24hr Composite	Summer
00552 - Oil and Grease, Hexane Extr Method - mg/l	10	-	-	-	-	-	-	1 / 2 Weeks	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	4.5	3.0	-	426	284	5/Week	24hr Composite	Summer
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	15	10	-	1420	947	5/Week	24hr Composite	Winter
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1 / 2 Weeks	24hr Composite	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00719 - Cyanide, Free - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01079 - Silver, Total Recoverable - ug/l	26	-	-	5.3	2.47	-	0.502	1 / 2 Weeks	24hr Composite	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units		Loading* kg/day					Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	1/Day	Grab	Summer
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50060 - Chlorine, Total Residual - mg/l	0.038	-	-	-	-	-	-	1/Day	Multiple Grab	Summer
50092 - Mercury, Total (Low Level) - ng/l	1700	-	-	12	0.161	-	0.00114	1/Month	Grab	All
61425 - Acute Toxicity, Ceriodaphnia dubia - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61426 - Chronic Toxicity, Ceriodaphnia dubia - TUC	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61427 - Acute Toxicity, Pimephales promelas - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61428 - Chronic Toxicity, Pimephales promelas - TUC	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Continuous	All
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Continuous	All
70300 - Residue, Total Filterable - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
80082 - CBOD 5 day - mg/l	-	-	33	22	-	3130	2090	4/Week	24hr Composite	Winter
80082 - CBOD 5 day - mg/l	-	-	23	15	-	2180	1420	4/Week	24hr Composite	Summer

NOTES for Station Number 1PE00007001:

* Effluent loadings based on average design flow of 25 MGD.

- Flow rates may be monitored at the effluent of the primary treatment system and reported at final outfall station 1PE00007001.
- Total residual chlorine - See Part II, Item P.
- Nickel, zinc, cadmium, lead, total chromium, copper, and silver - See Part II, Item T.
- Dissolved hexavalent chromium - See Part II, Item U.
- Mercury - See Part II, Items U and AA.
- Free cyanide - See Part II, Items U and Z.
- Whole effluent toxicity - See Part II, Item DD.

Part I, B. - DOWNSTREAM-FARFIELD MONITORING REQUIREMENTS

1. Downstream-Farfield Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor the receiving stream, downstream of the point of discharge, at Station Number 1PE00007900, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Downstream-Farfield Monitoring - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months		
Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly	
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Month	Grab	All
00300 - Dissolved Oxygen - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00400 - pH - S.U.	-	-	-	-	-	-	-	1/Month	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00900 - Hardness, Total (CaCO3) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
01079 - Silver, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	-	-	-	-	-	1/Month	Grab	Summer

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

2. CSO Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor at each combined sewer overflow station listed in Part II, Item D and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, Item D for locations of sampling.

Table - CSO Monitoring - 002 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	1/Year	Total	January
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	1/Year	Total	January

NOTES for combined sewer overflow stations listed in Part II, Item D:

- See Part II Item E for additional CSO monitoring requirements.
- See Part II Item F for additional reporting requirements.
- Data that is reported for this station may be generated using the City's predictive collection system model. A Monthly Operating Report (Form 4500) for this station shall be submitted once per year in January. The total number of overflow occurrences and total overflow volume for the preceding calendar year shall be reported. An Overflow Occurrence shall be defined as follows:
Overflow Occurrences - A discharge from this station that occurs intermittently during a day, starting and stopping several times, should be counted as one occurrence. A discharge from this station that occurs on more than one day but is the result of a continuous precipitation event should be counted as one occurrence.
- If there are no discharges during the entire year select the "No Discharge" check box on the data entry form. PIN the eDMR.
- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from these stations only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.

Part I, B. - BYPASS MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

3. Bypass Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor the treatment plant's bypass when discharging, at Station Number 1PE00007066, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Bypass Monitoring - 066 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00051 - Bypass Occurrence - No./Day	-	-	-	-	-	-	-	When Disch.	24hr Total	All
00052 - Bypass Total Hours Per Day - Hrs/Day	-	-	-	-	-	-	-	When Disch.	24hr Total	All
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	When Disch.	Composite	All
51428 - Bypass Volume - MGAL	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	When Disch.	Composite	All

NOTES for Station Number 1PE00007066:

- Data for 24 hour total flow, bypass occurrence(s) per day, and the bypass total hours per day may be estimated if a measuring device is not available.
- A Discharge Monitoring Report, or DMR (Form 4500) for this station must be submitted every month.
- Monitoring and sampling shall be conducted and reported on each day that there is a discharge through this station.
- If there are no discharges during the entire month, select the "No Discharge" check box on the data entry form. PIN the eDMR.
- Bypass Occurrence - If a discharge from this station occurs intermittently during a day, starting and stopping several times, report "1" for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence: Report "1" on the first day of the discharge.
- Discharge through this station is prohibited. The Director may take enforcement action for violations of this prohibition unless the three conditions specified at 40 CFR 122.41(m) and in Part III, Item 11.C.1 of this permit are met.

Part I, B. - BYPASS MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

4. Bypass Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor the treatment plant's bypass when discharging, at Station Number 1PE00007067, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Bypass Monitoring - 067 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00051 - Bypass Occurrence - No./Day	-	-	-	-	-	-	-	When Disch.	24hr Total	All
00052 - Bypass Total Hours Per Day - Hrs/Day	-	-	-	-	-	-	-	When Disch.	24hr Total	All
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	When Disch.	Composite	All
51428 - Bypass Volume - MGAL	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	When Disch.	Composite	All

NOTES for Station Number 1PE00007067:

- Data for 24 hour total flow, bypass occurrence(s) per day, and the bypass total hours per day may be estimated if a measuring device is not available.
- A Discharge Monitoring Report, or DMR (Form 4500) for this station must be submitted every month.
- Monitoring and sampling shall be conducted and reported on each day that there is a discharge through this station.
- If there are no discharges during the entire month, select the "No Discharge" check box on the data entry form. PIN the eDMR.
- Bypass Occurrence - If a discharge from this station occurs intermittently during a day, starting and stopping several times, report "1" for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence: Report "1" on the first day of the discharge.
- Discharge through this station is prohibited. The Director may take enforcement action for violations of this prohibition unless the three conditions specified at 40 CFR 122.41(m) and in Part III, Item 11.C.1 of this permit are met.

Part I, B. - SSO MONITORING EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

5. SSO Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor at Station Number 1PE00007300, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - SSO Monitoring - 300 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	1/Month	Total	All

NOTES for Station Number 1PE00007300:

- A sanitary sewer overflow is an overflow, spill, release, or diversion of waste water from a sanitary sewer system. These overflows shall be monitored when they discharge.
- For the purposes of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of waste water on a given day that enters waters of the state is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, record two occurrences for that day. If overflows from both locations continue on the following day, record two occurrences for the following day. At the end of the month, total the daily occurrences and report this number in the first column of the first day of the month on the 4500 form. If there are no overflows during the entire month, report "zero" (0).
- All sanitary sewer overflows are prohibited.
- See Part II, Items J and K.

Part I, B. - SLUDGE MONITORING REQUIREMENTS

6. Sludge Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor the treatment works' final sludge at Station Number 1PE00007581, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 581 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months		
Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly	
00611 - Ammonia (NH3) In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00627 - Nitrogen Kjeldahl, Total In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00668 - Phosphorus, Total In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00938 - Potassium In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01003 - Arsenic, Total In Sludge - mg/kg	75	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01028 - Cadmium, Total In Sludge - mg/kg	85	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01043 - Copper, Total In Sludge - mg/kg	4300	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01052 - Lead, Total In Sludge - mg/kg	840	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01068 - Nickel, Total In Sludge - mg/kg	420	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01093 - Zinc, Total In Sludge - mg/kg	7500	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01148 - Selenium, Total In Sludge - mg/kg	100	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
51129 - Sludge Fee Weight - dry tons	-	-	-	-	-	-	-	1/Quarter	Total	Quarterly - Alt.
51131 - Fecal Coliform in Sludge - CFU/gram	2000000	-	-	-	-	-	-	1/Quarter	Multiple Grab	Quarterly - Alt.
70316 - Sludge Weight - Dry Tons	-	-	-	-	-	-	-	1/Quarter	Total	Quarterly - Alt.
71921 - Mercury, Total In Sludge - mg/kg	57	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
78465 - Molybdenum In Sludge - mg/kg	75	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.

NOTES for Station Number 1PE00007581:

- Monitoring is required when sewage sludge is removed from the permittee's facility for application to the land. The monitoring data shall be reported on the March, June, September, and December Discharge Monitoring Report (DMR). The monitoring data can be collected at any time during the reporting period.

- Metal pollutant analysis must be completed during each reporting period, whether sewage sludge is removed from the facility or not, or the number of composite samples collected and reported shall be increased prior to the next land application event to account for the reporting period(s) in which land application did not occur, unless all previously accumulated sewage sludge has been removed and disposed of via a landfill, through incineration or by transfer to another treatment works.

- If no sewage sludge is removed from the facility during the reporting period, enter the results for the metal analysis in eDMR or on the 4500 report and enter "0" for sludge weight and sludge fee weight.

- If no sewage sludge is removed from the facility during the reporting period and no metal analysis is completed during the reporting period, the permittee shall select the "No Discharge" check box on the data entry form. PIN the eDMR.

- If metal analysis has not been completed previously during each reporting period: when sewage sludge is removed from the facility all metal analysis results shall be reported on the applicable DMR by entering the separate results on different days within the DMR. For example, if no sewage sludge has been removed from the facility for a full calendar year, and quarterly monitoring is required by the permit, then five (four from the previous year and one for the current monitoring period) separate composite samples of the sewage sludge are required to be collected and analyzed for metals prior to removal from the facility. The first sample result may be entered on the first day of the DMR, the second result on the second day of the DMR, and so on. A note may then be added to indicate the actual day(s) when the samples were collected.

- To sample for fecal coliform, the treatment plant should collect and analyze a grab sample every other day over a two week period for a total of seven grab samples when practical. Each of the grab samples shall be analyzed independently to determine the MPN/g (or CFU/g when applicable) of fecal coliform in the individual sample. The geometric mean of those seven results shall be reported on the DMR. Each fecal coliform sample must be delivered to the analytical lab within six hours after the sample has been collected, in accordance with the requirements for Part 9221 E. or part 9222 D., "Standard Methods for the Examination of Water and Wastewater". This process must be completed prior to sewage sludge being removed from the treatment facility.

- It is recommended that composite samples of the sewage sludge be collected and analyzed close enough to the time of land application to be reflective of the sludge's current quality, but not so close that the results of the analysis are not available prior to land applying the sludge.
- The permittee shall maintain the appropriate records on site to verify that the requirements of Pathogen Reduction and Vector Attraction Reduction have been met.
- Units of mg/kg are on a dry weight basis.
- Sludge weight is a calculated total for the year. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge: dry tons= gallons x 8.34 (lbs/gallon) x 0.0005 (tons/lb) x decimal fraction total solids.
- Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.
- See Part II, Items V, W, X and Y.

Part I, B. - SLUDGE MONITORING REQUIREMENTS

7. Sludge Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor the treatment works' final sludge at Station Number 1PE00007586, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 586 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
51129 - Sludge Fee Weight - dry tons	-	-	-	-	-	-	-	1/Year	Total	December

NOTES for Station Number 1PE00007586:

- Monitoring is required when sewage sludge is removed from the permittee's facility for disposal in a mixed solid waste landfill. The total Sludge Fee Weight of sewage sludge disposed of in a mixed solid waste landfill for the entire year shall be reported on the December Discharge Monitoring Report (DMR).

- If no sewage sludge is removed from the Permittee's facility for disposal in a mixed solid waste landfill during the year, select the "No Discharge" check box on the data entry form. PIN the eDMR.

- Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.

- See Part II, Items V, W, X and Y.

Part I, B. - INFLUENT MONITORING REQUIREMENTS

8. Influent Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor the treatment works' influent wastewater at Station Number 1PE00007601, and report to the Ohio EPA in accordance with the following table. Samples of influent used for determination of net values or percent removal must be taken the same day as those samples of effluent used for that determination. See Part II, OTHER REQUIREMENTS, for location of influent sampling.

Table - Influent Monitoring - 601 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units				Loading* kg/day		Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	4/Week	24hr Composite	All
00720 - Cyanide, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01079 - Silver, Total Recoverable - ug/l	-	-	-	-	-	-	-	1 / 2 Weeks	24hr Composite	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
50092 - Mercury, Total (Low Level) - ng/l	-	-	-	-	-	-	-	1/Month	Grab	All
61941 - pH, Maximum - S.U.	-	-	-	-	-	-	-	1/Day	Continuous	All
61942 - pH, Minimum - S.U.	-	-	-	-	-	-	-	1/Day	Continuous	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	4/Week	24hr Composite	All

NOTES for Station Number 1PE00007601:

- Nickel, zinc, cadmium, lead, total chromium, copper and silver - See Part II, Item T.
- Total cyanide and dissolved hexavalent chromium - See Part II, Item U.
- Mercury - See Part II, Items U and AA.

Part I, B. - UPSTREAM MONITORING REQUIREMENTS

9. Upstream Monitoring. During the period beginning on the effective date of this permit modification and lasting until the expiration date, the permittee shall monitor the receiving stream, upstream of the point of discharge at Station Number 1PE00007800, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Upstream Monitoring - 800 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Month	Grab	All
00300 - Dissolved Oxygen - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00400 - pH - S.U.	-	-	-	-	-	-	-	1/Month	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	-	-	-	-	-	1/Month	Grab	Summer
61432 - 48-Hr. Acute Toxicity Ceriodaphnia dubia - % Affected	-	-	-	-	-	-	-	1/Year	Grab	September
61435 - 96-Hr. Acute Toxicity Pimephales promela - % Affected	-	-	-	-	-	-	-	1/Year	Grab	September
61438 - 7-Day Chronic Toxicity Ceriodaphnia dubia - % Affected	-	-	-	-	-	-	-	1/Year	Grab	September
61441 - 7-Day Chronic Toxicity Pimephales promelas - % Affected	-	-	-	-	-	-	-	1/Year	Grab	September

NOTES for Station Number 1PE00007800:

- Whole effluent toxicity - See Part II, Item DD.

Part I, B. - UPSTREAM MONITORING REQUIREMENTS

10. Upstream Monitoring. During the period beginning on the effective date of the permit modification and lasting until the expiration date, the permittee shall monitor the receiving stream, upstream of the point of discharge at Station Number 1PE00007801, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Upstream Monitoring - 801 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Month	Grab	All
00300 - Dissolved Oxygen - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00400 - pH - S.U.	-	-	-	-	-	-	-	1/Month	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	-	-	-	-	-	1/Month	Grab	Summer

Part I, C - Schedule of Compliance

A. Municipal Pretreatment Schedule

1. The permittee shall evaluate the adequacy of local industrial user limitations to prevent the introduction of pollutants into the POTW which will interfere with the operation of the POTW, pass through the POTW, be incompatible with the POTW, or limit wastewater or sludge use options. Technical justification for revising local industrial user limitations to attain compliance with final table limits, along with a pretreatment program modification request, or technical justification for retaining existing local industrial user limitations shall be submitted to Ohio EPA, Central Office Pretreatment Unit, in duplicate, as soon as possible, but no later than June 1, 2015. (Event Code 52599) The permittee's local limit evaluation shall take place after substantial completion of plant construction and returning the septage receiving station to service.

Technical justification is required for silver. Technical justification is also required for arsenic, cadmium, total chromium, dissolved hexavalent chromium, copper, free cyanide, lead, molybdenum, nickel, selenium and zinc unless screening of wastewater and sludge indicate these pollutants are not present in significant amounts. Furthermore, technical justification is required for any other pollutants where a local limit may be necessary to protect against pass through and interference.

To demonstrate technical justification for new local industrial user limits or justification for retaining existing limits, the following information must be submitted to Ohio EPA:

- a. Treatment plant flow, domestic/background concentrations, loading from septage and industrial flows to which local limits will be applied.
- b. Treatment plant removal efficiencies.
- c. A comparison of maximum allowable headworks loadings based on all applicable criteria. Criteria may include sludge disposal, NPDES permit limits, waste load allocation values, and interference with biological processes such as activated sludge, sludge digestion, nitrification, etc.
- d. If revised industrial user discharge limits are proposed, the method of allocating available pollutant loads to industrial users. If an allocation method other than uniform concentration is proposed, the proposal must show how the available loads will be allocated to each industrial user or group of industrial users.
- e. Supporting data, assumptions, and methodologies used in establishing the information in Items 1.a through 1.d above.

Evaluation of Local Limit for Mercury

2. The permittee shall evaluate the adequacy of local industrial user limitations for mercury. A technical justification for revising local industrial user limitations, along with a pretreatment program modification request, or technical justification for retaining existing local industrial user limitations shall be submitted to Ohio EPA, Central Office Pretreatment Unit, in duplicate, as soon as possible, but no later than June 1, 2015. (Event Code 52599) The permittee's local limit evaluation shall take place after substantial completion of plant construction and returning the septage receiving station to service.

To demonstrate technical justification for a new local industrial user limit for mercury, or justification for retaining the existing limit, the following information must be submitted to Ohio EPA:

a. Treatment plant flow, domestic/background concentrations, loading from septage and industrial flows to which the local limit will be applied. When representative sampling of the collection system and industrial pollutant contributors conducted using EPA Method 245.1 or 245.2 shows mercury concentrations that are below detection, either EPA Method 1631 or 245.7 shall be used to quantify domestic/background and industrial pollutant contributions of mercury.

b. Treatment plant removal efficiencies. When representative sampling of the influent and effluent conducted using EPA Method 245.1 or 245.2 shows mercury concentrations that are below detection, either EPA Method 1631 or 245.7 shall be used to quantify influent and effluent mercury concentrations.

c. A comparison of maximum allowable headworks loadings based on all applicable criteria. Criteria may include sludge disposal, NPDES permit limits, waste load allocation values, and interference with biological processes such as activated sludge, sludge digestion, nitrification, etc.

d. If an industrial user discharge limit for mercury is proposed, the method of allocating the available mercury loads to industrial users. If an allocation method other than uniform concentration is proposed, the proposal must show how the available load will be allocated to each industrial user or group of industrial users.

When appropriate, industrial user discharge limits may include narrative local limits requiring industrial users to develop and implement best management practices for mercury. These narrative local limits may be used either alone or as a supplement to a numeric limit.

e. Supporting data, assumptions, and methodologies used in establishing the information in Items 2.a through 2.d above.

Silver Reduction Plan

3. If, in the evaluation of a local limit for silver, the available load is determined to be impracticable or ineffective in assuring compliance with the NPDES permit limit criteria, the City shall submit a plan with the local limits evaluation that identifies sources of silver other than from the industrial users identified in the local limits evaluation.

Potential sources may include process lines, non-significant industrial users, commercial and residential users, sewer lines and sediments, storm water inputs and hauled wastes. The plan shall include a program for reducing contributions from identified sources .

If the city develops a silver reduction plan, the city's annual pretreatment report shall include a summary of efforts and results associated with implementation of the plan. The summary shall include at least the following elements:

- a. All silver reduction program monitoring results for the year;
 - b. A list of known and potential sources of silver the reduction plan is or will be applicable to;
 - c. A summary of all actions taken to reduce silver contributions into the POTW;
 - d. A evaluation of the effectiveness of the plan over the previous year in reducing the amount of silver being recieved by and discharged from the POTW. A table or chart should be included with this evaluation; and
 - e. Any updates of the reduction plan.
4. If revisions to local industrial user limitations, including best management practices, are determined to be necessary, no later than 4 months after the date of Ohio EPA's approval, the permittee shall incorporate revised local industrial user limitations in all control documents of industrial users upon which the local limits were based and to which are applicable.

Minimizing Industrial User Impacts on Combined Sewer Overflows

5. In satisfying the requirement of Part II.G.3, the permittee shall actively work with, at a minimum, significant industrial users to establish cooperative agreements that will minimize, to the extent practicable, pollutant loads from their operations being discharged through combined sewer overflows (CSOs) during wet weather conditions.

These agreements shall consider all opportunities to minimize the impact of industrial user operations on CSOs including, but not limited to, delaying operations and/or discharges that contribute significant pollutant loadings and on-site flow equalization to allow flow attenuation during times when CSOs are active.

Cooperative agreements between the permittee and targeted industrial users developed as part of the permittee's control strategy shall include a description of the communication system (telemetry, phone calls, etc.) to be used to maximize the effectiveness of the controls included in agreements.

C. CSO Long-Term Control Plan Schedule

The City of Springfield shall complete implementation of the following projects as outlined in the City of Springfield, Ohio, CSO Long-Term Control Plan, Final Report (April 30, 2004) / Final Report Addendum (March 15, 2012) as approved by the Director on February 11, 2014 (Plan Approval Number 950177) as soon as possible, but not later than the dates developed in accordance with the following compliance schedule:

1. Construction Erie Interceptor Express Sewer.

- a. The permittee shall submit a Permit-to-Install application and detailed plans for construction of the Erie Interceptor Express Sewer as soon as possible, but not later than May 1, 2015. (Event Code 01299)
- b. The permittee shall advertise for bids on the Erie Interceptor Express Sewer as soon as possible, but not later than March 1, 2016. (Event Code 01899)
- c. The permittee shall begin construction of the Erie Interceptor Express Sewer as soon as possible, but not later than August 1, 2016. (Event Code 03099)
- d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.
- e. The permittee shall complete construction of the Erie Interceptor Express Sewer as soon as possible, but not later than September 30, 2018. (Event Code 04599)
- f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

g. The permittee shall attain operational level of the upgraded Erie Interceptor Express Sewer sewerage system as soon as possible, but not later than October 1, 2019. (Event Code 05599)

2. Construction High Rate Treatment Unit at Permit Outfall 1PE00007066 (DC01)

a. The permittee received Permit-to-Install approval (PTI number 837393) for construction of a High Rate Treatment Unit on May 3, 2012. Construction of the treatment unit began on August 28, 2012. The permittee shall complete construction as soon as possible, but not later than January 1, 2015. (Event Code 04599)

b. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

c. The permittee shall attain operational level of the treatment works and meet final effluent limitations as soon as possible, but not later than July 1, 2015. (Event Code 05599)

3. Tunnel Geotechnical Investigation.

a. The permittee shall initiate a geotechnical investigation to include preliminary borings as soon as possible, but not later than May 1, 2013.

b. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of commencing the geotechnical investigation.

c. The permittee shall complete geotechnical work, including detailed borings, as soon as possible, but not later than September 30, 2014.

d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing the geotechnical investigation.

e. The permittee shall submit a geotechnical investigation summary report, including detailed cost estimates, as soon as possible, but not later than December 31, 2014. (Event code 61099)

4. Programmatic Review.

a. As part of its adaptive management approach, the permittee shall initiate a programmatic review of all work completed as part of the LTCP phase 1 and 2 programs with respect to selected projects, sizing, subsequent projects and schedule updates beginning on June 1, 2015. A final report detailing the findings of this review must be submitted no later than December 31, 2016. (Event Code 61099)

5. No Feasible Alternatives Analysis Phase One.

a. The permittee shall continue stress testing of the various treatment units to determine operational conditions necessary to maintain complete secondary treatment for flows of up to 40 MGD. A summary report detailing the findings and specific operational conditions that must be maintained shall be submitted as soon as possible, but not later than November 1, 2013. (Event Code 11099)(COMPLETED)

b. Upon completing construction of the new High Rate Treatment (HRT) system and addition of a third secondary clarifier (July 1, 2015), the permittee shall begin to develop a Phase Two No Feasible Alternatives Analysis general plan for treatment system upgrades necessary to provide complete secondary treatment for flows up to 50 MGD. At a minimum, the plan shall look at storage through the HRT system, primary splitter box upgrades, primary effluent pumping capacity, trickling filter effluent pumping capacity, and disinfection treatment capacity. The general plan shall be submitted as soon as possible, but not later than December 1, 2015. (Event Code 53799)

c. The permittee shall submit an updated Phase Two No Feasible Alternatives Analysis (based upon the work completed up to the permit expiration date, July 31, 2017) as soon as possible, but not later than October 1, 2017 (Event Code 15099). The update shall consider the following:

1. design capacity for all treatment unit.
2. maximum flow per unit and feasibility of increasing flow.
3. estimate the frequency, duration, and volume of current wet weather diversions.
4. evaluate alternatives to reduce frequency, duration, and volume of occurrences.
5. estimate potential future peak wet weather diversions based upon weather, population, and collection and treatment upgrades.
6. assess storage opportunities to reduce frequency, duration, and volume of peak wet weather diversions.
7. assess reductions in peak wet weather flows through limiting sewer extensions or slug loadings from indirect dischargers.
8. evaluate other technologies, biological, physical, and chemical treatment to provide additional treatment to peak wet weather flows.
9. evaluate the extent to which the permittee is maximizing its ability to reduce I/I.
10. evaluate peak flow reductions obtainable through implementation of the CMOM program.
11. assess the community's ability to fund peak wet weather flow improvements.
12. expected improvements to the effluent, collection system, and plant performance should the technologies, practices, and/or other measures discussed in the NFA analysis be implemented.

6. Mill Creek Sewer Separation. (Note: Dates may be modified based upon June 30, 2016 programmatic review.)

a. The permittee shall submit a Permit-to-Install application and detailed plans for the construction of the Mill Creek sewer separation project as soon as possible, but no later than June 1, 2018. (Event Code 01899)

- b. The permittee shall advertise for bids for the Mill Creek separation project as soon as possible, but not later than November 1, 2018. (Event Code 01899)
- c. The permittee shall begin construction of the Mill Creek separation sewer as soon as possible, but not later than April 1, 2019
- d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.
- e. The permittee shall complete construction of the Mill Creek separation project as soon as possible, but not later than October 31, 2020. (Event Code 04599)
- f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

7. Mill Run Consolidation Sewer. (Note: Dates may be modified based upon June 30, 2016 programmatic review.)

- a. The permittee shall submit a Permit-to Install application and detailed plans for the construction of the Mill Run consolidation sewer project as soon as possible, but no later than March 1, 2020. (Event Code 01299)
- b. The permittee shall advertise for bids for the Mill Run consolidation sewer project as soon as possible, but not later than March 1, 2022. (Event Code 01899)
- c. The permittee shall begin construction of the Mill Run consolidation sewer as soon as possible, but not later than January 1, 2023. (Event Code 03099)
- d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.
- e. The permittee shall complete construction of the Mill Run consolidation sewer project as soon as possible, but not later than December 31, 2024. (Event Code 04599)
- f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

8. Upper Buck Creek Consolidation Sewer. (Note: Dates may be modified based upon June 30, 2016 programmatic review.)

- a. The permittee shall submit a Permit-to-Install application and detailed plans for the construction of the Upper Buck Creek consolidation sewer project as soon as possible, but no later than November 1, 2020. (Event Code 01299)
- b. The permittee shall advertise for bids for the Upper Buck Creek consolidation sewer project as soon as possible, but not later than November 1, 2022. (Event Code 01899)
- c. The permittee shall begin construction of the Upper Buck Creek consolidation sewer as soon as possible, but not later than September 1, 2023. (Event Code 03099)
- d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.
- e. The permittee shall complete construction of the Upper Buck Creek consolidation sewer as soon as possible, but not later than August 31, 2026. (Event Code 04599).
- f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

9. Construction DC 40 Tunnel. (Note: Project implementation is dependent upon findings of June 30, 2016 programmatic review.)

- a. The permittee shall submit a Permit-to-Install application and detail plans for construction of the DC 40 tunnel as soon as possible, but not later than November 1, 2019. (Event Code 01299)
- b. The permittee shall advertise for bids to construct the DC 40 tunnel as soon as possible, but not later than January 1, 2021. (Event Code 01899).
- c. The permittee shall begin construction of the DC 40 tunnel as soon as possible, but not later than November 1, 2021. (Event Code 03099).
- d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.
- e. The permittee shall complete construction of the DC 40 tunnel as soon as possible, but not later than October 30, 2024. (Event Code 04599).
- f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.
- g. The permittee shall attain operational level of the DC 40 tunnel as soon as possible, but not later than April 30, 2025. (Event Code 05599).

10. Construction Buck Creek Storage Tunnel. (Note: Project implementation is dependent upon findings of June 30, 2016 programmatic review.)

- a. The permittee shall submit a Permit-to-Install application and detail plans for construction of the Buck Creek storage tunnel as soon as possible, but not later than March 1, 2020. (Event Code 01299)
- b. The permittee shall advertise for bids to construct the Buck Creek storage tunnel as soon as possible, but not later than September 1, 2021. (Event Code 01899).
- c. The permittee shall begin construction of the Buck Creek storage tunnel as soon as possible, but not later than July 1, 2022. (Event Code 03099).
- d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.
- e. The permittee shall complete construction of the Buck Creek storage tunnel as soon as possible, but not later than June 30, 2025. (Event Code 04599).
- f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.
- g. The permittee shall attain operational level of the Buck Creek storage tunnel as soon as possible, but not later than January 1, 2026. (Event Code 05599).

11. Construction Satellite High Rate Treatment System. (Note: Project implementation is dependent upon findings of June 30, 2016 programmatic review.)

- a. The permittee shall submit a Permit-to Install application and detailed plans for the construction of the Satellite High Rate Treatment system as soon as possible, but no later than March 1, 2019. (Event Code 01299)
- b. The permittee shall advertise for bids for construction of the Satellite High Rate Treatment system as soon as possible, but not later than January 1, 2020. (Event Code 01899)
- c. The permittee shall begin construction of the Satellite High Rate Treatment system as soon as possible, but not later than November 1, 2020. (Event Code 03099)
- d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.
- e. The permittee shall complete construction of the Satellite High Rate Treatment system as soon as possible, but not later than October 30, 2022. (Event Code 04599)
- f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

g. The permittee shall attain operational level of the Satellite High Rate Treatment system and meet final effluent limitations as soon as possible, but not later than May 1, 2023. (Event Code 05599)

12. Programmatic Review

a. As part of its adaptive management approach, the permittee shall initiate a programmatic review of all work completed as part of the LTCP phase 3 and 4 programs with respect to selected projects, sizing, subsequent projects and schedule updates beginning on November 1, 2021. A final report detailing the findings of this review must be submitted no later than October 31, 2022. (Event Code 61099)

13. Lower Buck Creek Sewer Separation. (Note: Project implementation is dependent upon finding of the October 31, 2022 programmatic review.)

a. The permittee shall submit a Permit-to-Install application and detailed plans for the construction of the Lower Buck Creek sewer separation as soon as possible, but no later than March 1, 2024. (Event Code 01299)

b. The permittee shall advertise for bids for construction of the Lower Buck Creek sewer separation as soon as possible, but not later than March 1, 2025. (Event Code 01899)

c. The permittee shall begin construction of the Lower Buck Creek sewer separation as soon as possible, but not later than January 1, 2026. (Event Code 03099)

d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction

e. The permittee shall complete construction of the Lower Buck Creek sewer separation project as soon as possible, but not later than June 30, 2029. (Event Code 04599).

f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

14. Lower Buck Creek Consolidation Sewer. (Note: Project implementation is dependent upon finding of the October 31, 2022 programmatic review.)

a. The permittee shall submit a Permit-to-Install application and detailed plans for construction of the Lower Buck Creek consolidation sewer as soon as possible, but not later than September 1, 2025. (Event Code 01299)

b. The permittee shall advertise for bids to construct the Lower Buck Creek consolidation sewer as soon as possible, but not later than March 1, 2027. (Event Code 01899).

c. The permittee shall begin construction of the Lower Buck Creek consolidation sewer as soon as possible but not later than January 1, 2028. (Event Code 03099)

d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.

e. The permittee shall complete construction of the Lower Buck Creek consolidation sewer as soon as possible but not later than December 31, 2030. (Event code 04599).

f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

g. The permittee shall attain operational level of the Lower Buck Creek consolidation sewer as soon as possible, but not later than July 1, 2031. (Event Code 05599).

15. Indian Run Consolidation Sewer. (Note: Project implementation is dependent upon finding of the October 31, 2022 programmatic review.)

a. The permittee shall submit a Permit-to-Install application and detailed plans for construction of the Indian Run consolidation sewer as soon as possible, but not later than June 1, 2026. (Event Code 01299)

b. The permittee shall advertise for bids to construct the Indian Run consolidation sewer as soon as possible, but not later than June 1, 2028. (Event Code 01899).

c. The permittee shall begin construction of the Indian Run consolidation sewer as soon as possible but not later than April 1, 2029. (Event Code 03099)

d. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of beginning construction.

e. The permittee shall complete construction of the Indian Run consolidation sewer as soon as possible but not later than December 31, 2030. (Event code 04599).

f. The permittee shall notify the Ohio EPA Southwest District Office within 7 days of completing construction.

g. The permittee shall attain operational level of the Indian Run consolidation sewer as soon as possible, but not later than July 1, 2031. (Event Code 05599).

16. Programmatic Review.

a. As part of its adaptive management approach, the permittee shall initiate a programmatic review of all work completed as part of the LTCP phase 5 program with respect to selected projects, sizing, subsequent projects and schedule updates beginning on November 1, 2026. A final report detailing the findings of this review must be submitted no later than October 31, 2027. (Event Code 61099)

17. As part of the annual CSO report required by Part II, Item F of this permit, the permittee will be submitting a summary of actions taken during the preceding calendar year to implement its "CSO Long-Term Control Plan, Final Report" (April 30, 2004)/"Final Report Addendum " (March 15, 2012). The annual report is due no later than January 31 of each year and will fulfill the twelve month reporting requirement of this compliance schedule.

18. This permit may be modified or revoked and reissued, as provided pursuant to 40 CFR 122.62 and 124.5 and rule 3745-33-04 of the Ohio Administrative Code, for the following reasons:

- To include new or revised conditions developed to comply with any State or Federal law or regulation that addresses collection system overflows or wastewater treatment plant bypasses that is adopted or promulgated after the effective date of this permit.

- To include new or revised conditions if new information, not available at the time of permit issuance, indicates that bypass controls imposed under the permit have failed to ensure compliance with 40 CFR 122.41(m).

- To include new or revised conditions based on new information generated from development and implementation of the permittee's No Feasible Alternatives analysis.

In addition, this permit may be modified or revoked and reissued for any reason specified in 40 CFR 122.62 and rule 3745-33-04 of the Ohio Administrative Code.

19. This permit, Ohio EPA permit number 1PE00007*OD, expires on July 31, 2017. Compliance schedule items 5.c (Updated NFA Analysis), 6.b - f (Mill Creek Sewer Separation), 7 (Mill Run Consolidation Sewer), 8 (Upper Buck Creek Consolidation Sewer), 9 (D.C. 40 Tunnel), 10 (Buck Creek Storage Tunnel), 11 (Satellite High Rate Treatment System), 12 (Programmatic Review), 13 (Lower Buck Creek Sewer Separation), 14 (Lower Buck Creek Consolidation Sewer), 15 (Indian Run Consolidation Sewer), and 16 (Programmatic Review) extend beyond the term of the permit. These items, including the compliance dates (subject to the findings of the 2016 and 2022 programmatic reviews) will be included in permit 1PE00007 when it is modified or renewed.

Part II, Other Requirements

A. Operator Certification Requirements

1. Classification

- a. In accordance with Ohio Administrative Code 3745-7-04, the sewage treatment facility at this facility shall be classified as a Class IV facility.
- b. All sewerage (collection) systems that are tributary to this treatment works are Class II sewerage systems in accordance with paragraph (B)(1)(a) of rule 3745-7-04 of the Ohio Administrative Code.

2. Operator of Record

- a. The permittee shall designate one or more operator of record to oversee the technical operation of the treatment works and sewerage (collection) system in accordance with paragraph (A)(2) of rule 3745-7-02 of the Ohio Administrative Code.
- b. Each operator of record shall have a valid certification of a class equal to or greater than the classification of the treatment works as defined in Part II, Item A.1 of this NPDES permit.
- c. Within three days of a change in an operator of record, the permittee shall notify the Director of the Ohio EPA of any such change on a form acceptable to Ohio EPA. The appropriate form can be found at the following website:

<http://epa.ohio.gov/portals/28/Documents/opcert/Operator%20of%20Record%20Notification%20Form.pdf>

- d. Within 60 days of the effective date of this permit, the permittee shall notify the Director of Ohio EPA of the operators of record on a form acceptable to Ohio EPA.
- e. The operator of record for a class II, III, or IV treatment works or class II sewerage system may be replaced by a backup operator with a certificate one classification lower than the treatment works or sewerage system for a period of up to thirty consecutive days. The use of this provision does not require notification to the agency.
- f. Upon proper justification, such as military leave or long term illness, the director may authorize the replacement of the operator of record for a class II, III, or IV treatment works or class II sewerage system by a backup operator with a certificate one classification lower than the facility for a period of greater than thirty consecutive days. Such requests shall be made in writing to the appropriate district office.

3. Minimum Staffing Requirements

a. The permittee shall ensure that the treatment works operator of record is physically present at the facility in accordance with the minimum staffing requirements per paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code or the requirements from an approved 3745-7-04(C) minimum staffing hour reduction plan.

b. Sewerage (collection) system Operators of Record are not required to meet minimum staffing requirements in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code.

c. If Ohio EPA approves a reduction in minimum staffing requirements based upon a facility operating plan, any change in the criteria under which the operating plan was approved (such as enforcement status, history of noncompliance, or provisions included in the plan) will require that the treatment works immediately return to the minimum staffing requirements included in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code.

B. The plant must be staffed and operated in accordance with the Ohio EPA approved Operation and Maintenance Manual.

C. Description of the location of the required sampling stations are as follows:

Sampling Station	Description of Location
1PE00007001	Final effluent to Mad River. (Lat: 39 N 54 ' 56 " ; Long: 83 W 51 ' 03 ").
1PE00007002	Combined sewer overflow. See Part II, Item D
1PE00007003	Combined sewer overflow. See Part II, Item D
1PE00007004	Combined sewer overflow. See Part II, Item D
1PE00007005	Combined sewer overflow. See Part II, Item D
1PE00007006	Combined sewer overflow. See Part II, Item D
1PE00007007	Combined sewer overflow. See Part II, Item D
1PE00007008	Combined sewer overflow. See Part II, Item D
1PE00007010	Combined sewer overflow. See Part II, Item D
1PE00007011	Combined sewer overflow. See Part II, Item D
1PE00007012	Combined sewer overflow. See Part II, Item D
1PE00007013	Combined sewer overflow. See Part II, Item D
1PE00007014	Combined sewer overflow. See Part II, Item D
1PE00007015	Combined sewer overflow. See Part II, Item D
1PE00007017	Combined sewer overflow. See Part II, Item D
1PE00007018	Combined sewer overflow. See Part II, Item D
1PE00007019	Combined sewer overflow. See Part II, Item D
1PE00007020	Combined sewer overflow. See Part II, Item D
1PE00007021	Combined sewer overflow. See Part II, Item D

1PE00007022	Combined sewer overflow. See Part II, Item D
1PE00007023	Combined sewer overflow. See Part II, Item D
1PE00007024	Combined sewer overflow. See Part II, Item D
1PE00007025	Combined sewer overflow. See Part II, Item D
1PE00007026	Combined sewer overflow. See Part II, Item D
1PE00007027	Combined sewer overflow. See Part II, Item D
1PE00007028	Combined sewer overflow. See Part II, Item D
1PE00007029	Combined sewer overflow. See Part II, Item D
1PE00007030	Combined sewer overflow. See Part II, Item D
1PE00007031	Combined sewer overflow. See Part II, Item D
1PE00007032	Combined sewer overflow. See Part II, Item D
1PE00007033	Combined sewer overflow. See Part II, Item D
1PE00007034	Combined sewer overflow. See Part II, Item D
1PE00007035	Combined sewer overflow. See Part II, Item D
1PE00007036	Combined sewer overflow. See Part II, Item D
1PE00007037	Combined sewer overflow. See Part II, Item D
1PE00007038	Combined sewer overflow. See Part II, Item D
1PE00007039	Combined sewer overflow. See Part II, Item D
1PE00007040	Combined sewer overflow. See Part II, Item D
1PE00007041	Combined sewer overflow. See Part II, Item D
1PE00007042	Combined sewer overflow. See Part II, Item D
1PE00007043	Combined sewer overflow. See Part II, Item D
1PE00007044	Combined sewer overflow. See Part II, Item D
1PE00007045	Combined sewer overflow. See Part II, Item D
1PE00007046	Combined sewer overflow. See Part II, Item D
1PE00007047	Combined sewer overflow. See Part II, Item D
1PE00007050	Combined sewer overflow. See Part II, Item D
1PE00007053	Combined sewer overflow. See Part II, Item D
1PE00007055	Combined sewer overflow. See Part II, Item D
1PE00007056	Combined sewer overflow. See Part II, Item D
1PE00007057	Combined sewer overflow. See Part II, Item D
1PE00007059	Combined sewer overflow. See Part II, Item D
1PE00007062	Combined sewer overflow. See Part II, Item D
1PE00007066	Treatment plant influent bypass through horizontal screening to Mad River.
1PE00007067	Treatment plant secondary bypass after primary clarification to Mad River.
1PE00007068	Combined sewer overflow. See Part II, Item D
1PE00007069	Combined sewer overflow. See Part II, Item D
1PE00007070	Combined sewer overflow. See Part II, Item D
1PE00007082	Combined sewer overflow. See Part II, Item D

1PE00007083	Combined sewer overflow. See Part II, Item D
1PE00007300	System wide sanitary sewer overflow occurrences.
1PE00007581	Sludge to land disposal.
1PE00007586	Sludge disposal by landfilling.
1PE00007601	Raw sewage influent prior to influent screens.
1PE00007800	Mad River upstream from the confluence with Buck Creek at the Route 40 bridge.
1PE00007801	Buck Creek upstream from the confluence with Mad River.
1PE00007900	Mad River downstream from outfall 1PE00007001 at Old Mill Road.

D. Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from these stations only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system. See Part I, B and Part II, Items E and F for monitoring and reporting requirements. Also see Part III, Item 11.

Station Number	Description	Receiving Stream
1PE00007002	Sigler St. & Pleasant St.	Ditch to Mad River
1PE00007003	Main St. & Buck Creek	Buck Creek
1PE00007004	Avenue B & Harshman Blvd.	Buck Creek
1PE00007005	Snyder St. & Overlook Dr.	Buck Creek
1PE00007006	Bechtle Ave. & Kinsman Ave.	Buck Creek
1PE00007007	Klobdenz Ave.	Buck Creek
1PE00007008	Main St. & Bell Ave.	Buck Creek
1PE00007010	Shaffer St. in Snyder Pk.	Buck Creek
1PE00007011	DT&I Railroad in Snyder Pk.	Buck Creek
1PE00007012	McCreight Ave. & Yellow Spr.	Buck Creek
1PE00007013	S. of Buck Ck. E. of Plum St.	Buck Creek
1PE00007014	E. of Plum St. N. of Buck Ck.	Buck Creek
1PE00007015	Ward St. E. of Plum St.	Buck Creek
1PE00007017	Rockway St. at Buck Ck.	Buck Creek
1PE00007018	Rockway St.	Buck Creek
1PE00007019	Fountain Ave. & Ferncliff Pl.	Buck Creek
1PE00007020	Fountain Ave. & Warder St.	Buck Creek
1PE00007021	Warder St. W. of Limestone St.	Buck Creek
1PE00007022	Limestone St. & Warder st.	Buck Creek
1PE00007023	S. of Buck Ck. W. of Water	Buck Creek

1PE00007024	Water St. brdg. S. of Buck Ck.	Buck Creek
1PE00007025	E. of Water St. at Spencer	Buck Creek
1PE00007026	Warder St. W. of Power St.	Buck Creek
1PE00007027	Front St. at Chestnut St.	Buck Creek
1PE00007028	Front St. S. of Sher. N. Buck	Buck Creek
1PE00007029	Sherman Ave. brdg. E. Buck	Buck Creek
1PE00007030	Northern Ave. & Cedarview	Ditch to Buck Creek
1PE00007031	Northern Ave. & Cedarview E.	Ditch to Buck Creek
1PE00007032	Park Ave. S. of Buck Ck.	Buck Creek
1PE00007033	E. of Park Ave. at James	Buck Creek
1PE00007034	W. of Belmont at Henry St.	Buck Creek
1PE00007035	W. of Belmont brdg. S. Buck	Buck Creek
1PE00007036	Lagonda Ave. N. of Buck Ck.	Buck Creek
1PE00007037	CCC & St. Louis. R.R.	Buck Creek
1PE00007038	Burnett Rd. at DT&I R.R.	Channel to Buck Creek
1PE00007039	Main St. at DT&I R.R.	Ditch to Buck Creek
1PE00007040	Penn and Section St.	Buck Creek
1PE00007041	East St. & DT& I R.R.	Mill Run
1PE00007042	East St. & CCC & St. Louis R.R.	Mill Run
1PE00007043	East St. & Harrison St.	Mill Run
1PE00007044	E. of East St. & S. of Harrison St.	Mill Run
1PE00007045	Pine St. & CCC & St. Louis R.R.	Mill Run
1PE00007046	Lafayett St. & CCC & St. Louis R.R.	Mill Run
1PE00007047	Burt St. & R.R., S of Mill Run	Mill Run
1PE00007050	Burt St. & R.R., N of Mill Run	Mill Run
1PE00007053	Belmont Ave. & Kenton St.	Mill Run
1PE00007055	Sheridan Ave. & Belmont Ave.	Mill Run
1PE00007056	Douglas Ave. extension at Mill Run	Mill Run
1PE00007057A	Douglas Ave. extension at Mill Run	Mill Run
1PE00007057B	Douglas Ave. extension at Mill Run	Mill Run
1PE00007059	W. of Sturgeon St., S of city limits	Mill Creek
1PE00007062	Malden Ave. & Shelby Dr.	Ditch
1PE00007068	Levee Rd. & Wayne Ave	Buck Creek
1PE00007069	Water Front & Warder St.	Buck Creek
1PE00007070	Rockway St. Tunnel	Buck Creek
1PE00007082	Behind 232W. Auburn Ave.	Mill Run
1PE00007083	York St. at Mill Run	Mill Run

(Previously designated as CSO 1PE00007067)

E. The permittee shall set up a rotating schedule to monitor the systems CSO overflows at Stations 1PE00007002 through 1PE00007083. At least five (5) stations should be monitored during a storm event. Samples should be collected during the first 30 minutes of discharge. On an annual basis all CSO's shall be monitored at least once, except for those CSO's where physical constraints or safety concerns limit access. All limited access CSO's shall be identified in the annual report.

Monitoring data shall be submitted annually with the CSO annual summary report.

The rotational monitoring shall be conducted in accordance with the following table:

Reporting Code	Units	Parameter	Measurement Frequency	Sample Type
00530	mg/l	Suspended Solids	1/Month	Grab
74062	No/Month	Overflow Occurrence	When discharging	Estimate
74063	Million gallons	Overflow Volume	When discharging	Estimate
80082	mg/l	CBOD5	1/Month	Grab
80999	Hours	Duration	When discharging	Estimate

F. Not later than January 31 of each calendar year, the permittee shall submit two copies of a report summarizing its combined sewer overflow (CSO) discharges and CSO control activities during the previous year. One copy of the report shall be sent to the Ohio EPA, Division of Surface Water, Permits and Compliance Unit, P.O. Box 1049, Columbus, Ohio, 43216-1049; and one copy shall be sent to the Ohio EPA Southwest District Office. The report shall include:

- 1) An annual summary of the frequency and volume of CSO discharges and the total annual loadings for 5-day CBOD and total suspended solids. Information shall be provided for each CSO station. The data shall be reported in the tabular format provided by Ohio EPA. Data for this annual summary may be generated by the City's predictive collection system model using daily inputs of rainfall volume and duration for the previous calendar year.
- 2) The monitoring data required by Part II, Item E.
- 3) A summary of actions taken during the preceding calendar year to implement the nine minimum controls in accordance with the combined sewer system operational plan that was submitted to Ohio EPA on July 30, 1998. This will include an evaluation of the need to modify the operational plan to reflect changes in the collection system, changes in operation and maintenance procedures, or other changes in activities required under the plan.
- 4) A summary of actions taken during the preceding calendar year to implement the City's " CSO Long-Term Control Plan, Final Report" (April 30, 2004)/"Final Report Addendum " (March 15, 2012).

5) An evaluation of the City's predictive collection system model and the need to edit the model's data file or modify the program based upon changes within the sewer system. The evaluation shall include: a) a summary of revisions to the model that have been made based on the addition of sanitary sewers, elimination of storm sewer flow, changes in pumping capacities, or other changes to the wastewater treatment system or service area that are accounted for in the model's datafile or program; and, b) an evaluation of the model's accuracy and recalibration of the model, if necessary.

G. The entire wastewater treatment system shall be operated and maintained so that the total loading of pollutants discharged during wet weather is minimized. To accomplish this, the permittee shall utilize the following technologies:

- 1) provide proper operation and maintenance for the collection system and the combined sewer overflow points;
- 2) provide the maximum use of the collection system for storage of wet weather flow prior to allowing overflows;
- 3) review and modify the pretreatment program to minimize the impact of nondomestic discharges from combined sewer overflows;
- 4) maximize the capabilities of the POTW to treat wet weather flows, and maximize the wet weather flow to the wastewater treatment plant within the limits of the plant's capabilities;
- 5) prohibit dry weather overflows;
- 6) control solid and floatable materials in the combined sewer overflow discharge;
- 7) conduct required inspection, monitoring and reporting of CSOs;
- 8) implement pollution prevention programs that focus on reducing the level of contaminants in CSOs; and
- 9) implements a public notification program for areas affected by CSOs, especially beaches and recreation areas.

H. The City of Springfield submitted a "CSO Long-Term Control Plan, Final Report" (April 30, 2004)/"Final Report Addendum " (March 15, 2012) to Ohio EPA. This plan has not been approved and currently is under review by the Agency. This NPDES permit may be modified, or alternatively revoked and reissued, to incorporate additional provisions and conditions for implementing the long-term control plan once the plan has been approved by the Director. Approval and implementation of the long-term control plan may be addressed through a consent decree or other enforceable mechanism in lieu of incorporating provisions and conditions in this NPDES permit.

I. All parameters, except flow, need not be monitored on days when the plant is not normally staffed (Saturdays, Sundays, and Holidays). On those days, report "AN" on the monthly report form.

J. Sanitary Sewer Overflow (SSO) Reporting Requirements

A sanitary sewer overflow is an overflow, spill, release, or diversion of wastewater from a sanitary sewer system. SSOs do not include wet weather discharges from combined sewer overflows specifically listed in Part II of this NPDES permit (if any). All SSOs are prohibited.

1. Reporting for SSOs That Imminently and Substantially Endanger Human Health

a) Immediate Notification

You must notify Ohio EPA (1-800-282-9378) and the appropriate Board of Health (i.e., city or county) within 24 hours of learning of any SSO from your sewers or from your maintenance contract areas that may imminently and substantially endanger human health. The telephone report must identify the location, estimated volume and receiving water, if any, of the overflow. An SSO that may imminently and substantially endanger human health includes dry weather overflows, major line breaks, overflow events that result in fish kills or other significant harm, overflows that expose the general public to contact with raw sewage, and overflow events that occur in sensitive waters and high exposure areas such as protection areas for public drinking water intakes and waters where primary contact recreation occurs.

b) Follow-Up Written Report

Within 5 days of the time you become aware of any SSO that may imminently and substantially endanger human health, you must provide the appropriate Ohio EPA district office a written report that includes:

- (i) the estimated date and time when the overflow began and stopped or will be stopped (if known);
- (ii) the location of the SSO including an identification number or designation if one exists
- (iii) the receiving water (if there is one);
- (iv) an estimate of the volume of the SSO (if known);
- (v) a description of the sewer system component from which the release occurred (e.g., manhole, constructed overflow pipe, crack in pipe);
- (vi) the cause or suspected cause of the overflow;
- (vii) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the overflow and a schedule of major milestones for those steps; and
- (viii) steps taken or planned to mitigate the impact(s) of the overflow and a schedule of major milestones for those steps.

A document showing the acceptable format for a 5-day follow up written report can be downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance web page at http://epa.ohio.gov/dsw/permits/technical_assistance.aspx .

2. Reporting for All SSOs, Including Those That Imminently and Substantially Endanger Human Health

a) Monthly Operating Reports

Sanitary sewer overflows that enter waters of the state, either directly or through a storm sewer or other conveyance, shall be reported on your monthly operating reports. You must report the system-wide number of occurrences for SSOs that enter waters of the state in accordance with the requirements for station number 300. A monitoring table for this station is included in Part I, B of this NPDES permit. For the purpose of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, you should record two occurrences for that day. If overflows from both locations continue on the following day, you should record two occurrences for the following day. At the end of the month, total the daily occurrences from all locations on your system and report this number using reporting code 74062 (Overflow Occurrence, No./Month) on the 4500 form for station number 300.

b) Annual Report

You must prepare an annual report of all SSOs in your collection system, including those that do not enter waters of the state. The annual report must be in an acceptable format (see below) and must include:

- (i) A table that lists an identification number, a location description, and the receiving water (if any) for each existing SSO. If an SSO previously included in the list has been eliminated, this shall be noted. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.
- (ii) A table that lists the date that an overflow occurred, the unique ID of the overflow, the name of affected receiving waters (if any), and the estimated volume of the overflow (in millions of gallons). The annual report may summarize information regarding overflows of less than approximately 1,000 gallons.
- (iii) A table that summarizes the occurrence of water in basements (WIBs) by total number and by sewershed. The report shall include a narrative analysis of WIB patterns by location, frequency and cause. Only WIBs caused by a problem in the publicly-owned collection system must be included.

Not later than March 31 of each year, you must submit one copy of the annual report for the previous calendar year to the appropriate Ohio EPA district office and one copy to: Ohio EPA; Division of Surface Water; NPDES Permit Unit; P.O. Box 1049; Columbus, OH, 43216-1049. You also must provide adequate notice to the public of the availability of the report.

A document showing the acceptable format for an annual SSO report can be downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance web page at http://epa.ohio.gov/dsw/permits/technical_assistance.aspx .

K. The permittee shall maintain in good working order and operate as efficiently as possible the "treatment works" and "sewerage system" as defined in ORC 6111.01 to achieve compliance with the terms and conditions of this permit and to prevent discharges to the waters of the state, surface of the ground, basements, homes, buildings, etc.

L. Composite samples shall be comprised of a series of grab samples collected over a 24-hour period and proportionate in volume to the sewage flow rate at the time of sampling. Such samples shall be collected at such times and locations, and in such a fashion, as to be representative of the facility's overall performance.

M. Grab samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's performance.

N. Multiple grab samples shall be comprised of at least three grab samples collected at intervals of at least three hours during the period that the plant is staffed on each day for sampling. Samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance. The critical value shall be reported.

O. The treatment works must obtain at least 85 percent removal of carbonaceous biochemical oxygen demand (five-day) and suspended solids (see Part III, Item 1).

P. The parameters below have had effluent limitations established that are below the Ohio EPA Quantification Level (OEPA QL) for the approved analytical procedure promulgated at 40 CFR 136. OEPA QLs may be expressed as Practical Quantification Levels (PQL) or Minimum Levels (ML).

Compliance with an effluent limit that is below the OEPA QL is determined in accordance with ORC Section 6111.13 and OAC Rule 3745-33-07(C). For maximum effluent limits, any value reported below the OEPA QL shall be considered in compliance with the effluent limit. For average effluent limits, compliance shall be determined by taking the arithmetic mean of values reported for a specified averaging period, using zero (0) for any value reported at a concentration less than the OEPA QL, and comparing that mean to the appropriate average effluent limit. An arithmetic mean that is less than or equal to the average effluent limit shall be considered in compliance with that limit.

The permittee must utilize the lowest available detection method currently approved under 40 CFR Part 136 for monitoring these parameters.

REPORTING:

All analytical results, even those below the OEPA QL (listed below), shall be reported. Analytical results are to be reported as follows:

1. Results above the QL: Report the analytical result for the parameter of concern.
2. Results above the MDL, but below the QL: Report the analytical result, even though it is below the QL.
3. Results below the MDL: Analytical results below the method detection limit shall be reported as "below detection" using the reporting code "AA".

The following table of quantification levels will be used to determine compliance with NPDES permit limits:

Parameter	PQL	ML
Chlorine, tot. res.	0.050 mg/l	--

This permit may be modified, or, alternatively, revoked and reissued, to include more stringent effluent limits or conditions if information generated as a result of the conditions of this permit indicate the presence of these pollutants in the discharge at levels above the water quality based effluent limit (WQBEL).

Q. POTWs that accept hazardous wastes by truck, rail, or dedicated pipeline are considered to be hazardous waste treatment, storage, and disposal facilities (TSDFs) and are subject to regulation under the Resource Conservation and Recovery Act (RCRA). Under the "permit-by-rule" regulation found at 40 CFR 270.60(c), a POTW must:

- 1) comply with all conditions of its NPDES permit,
- 2) obtain a RCRA ID number and comply with certain manifest and reporting requirements under RCRA,
- 3) satisfy corrective action requirements, and
- 4) meet all federal, state, and local pretreatment requirements.

R. Final permit limitations based on preliminary or approved waste load allocations are subject to change based on modifications to or finalization of the allocation or report or changes to Water Quality Standards. Monitoring requirements and/or special conditions of this permit are subject to change based on regulatory or policy changes.

S. This permit may be modified or revoked and reissued to include new or revised effluent limits or other conditions that are necessary to comply with an approved total maximum daily loads report (TMDL) as required under Section 303(d) of the Clean Water Act.

T. Sampling for these parameters at stations 1PE00007601 and 1PE00007001 shall occur on the same day.

U. Sampling at station 1PE00007601 for these parameters shall occur approximately one detention time (the time it takes for a volume of water to travel through the treatment plant) prior to sampling for them at station 1PE00007001.

V. All disposal, use, storage, or treatment of sewage sludge by the Permittee shall comply with Chapter 6111. of the Ohio Revised Code, Chapter 3745-40 of the Ohio Administrative Code and any further requirements specified in this NPDES permit, and any other actions of the Director that pertain to the disposal, use, storage, or treatment of sewage sludge by the Permittee.

W. Sewage sludge composite samples shall consist of a minimum of six grab samples collected at such times and locations, and in such fashion, as to be representative of the facility's sewage sludge.

X. No later than January 31 of each calendar year, the Permittee shall submit two (2) copies of a report summarizing the sewage sludge disposal, use, storage, or treatment activities of the Permittee during the previous calendar year. One copy of the report shall be sent to the Ohio EPA, Division of Surface Water, P.O. Box 1049, Columbus, Ohio 43216-1049, and one copy of the report shall be sent to the Southwest Ohio EPA District Office. The report shall be submitted on Ohio EPA Form 4229.

Y. Each day when sewage sludge is removed from the wastewater treatment plant for use or disposal, a representative sample of sewage sludge shall be collected and analyzed for percent total solids. This value of percent total solids shall be used to calculate the total Sewage Sludge Weight (Discharge Monitoring Report code 70316) and/or total Sewage Sludge Fee Weight (Discharge Monitoring Report code 51129) removed from the treatment plant on that day. The results of the daily monitoring, and the weight calculations, shall be maintained on site for a minimum of five years. The test methodology used shall be from Part 2540 G of Standard Methods for the Examination of Water and Wastewater American Public Health Association, American Water Works Association, and Water Environment Federation, using the edition which is current on the issuance date of the permit. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge: $\text{dry tons} = \text{gallons} \times 8.34 \text{ (lbs/gallon)} \times 0.0005 \text{ (tons/lb)} \times \text{decimal fraction total solids}$.

Z. It is understood by Ohio EPA that at the time permit 1PE00007*OD becomes effective, an analytical method is not approved under 40 CFR 136 to comply with the free cyanide monitoring requirements included in the permit. The permittee shall utilize method 4500-CN I in the 18th, 19th or 20th edition of Standard Methods.

AA. The permittee shall use either EPA Method 1631 or EPA Method 245.7 promulgated under 40 CFR 136 to comply with the influent and effluent mercury monitoring requirements of this permit.

BB. Pretreatment Program Requirements

The permittee's pretreatment program initially approved on March 1, 1985 and all subsequent modifications approved before the effective date of this permit, shall be an enforceable term and condition of this permit.

To ensure that the approved program is implemented in accordance with 40 CFR 403, Chapter 3745-3 of Ohio Administrative Code and Chapter 6111 of the Ohio Revised Code, the permittee shall comply with the following conditions:

1. Legal Authority

The permittee shall adopt and maintain legal authority which enables it to fully implement and enforce all aspects of its approved pretreatment program including the identification and characterization of industrial sources, issuance of control documents, compliance monitoring and reporting, and enforcement.

The permittee shall establish agreements with all contributing jurisdictions, as necessary, to enable the permittee to fulfill its requirements with respect to industrial users discharging to its system.

2. Industrial User Inventory

The permittee shall identify all industrial users subject to pretreatment standards and requirements and characterize the nature and volume of pollutants in their wastewater. Dischargers determined to be Significant Industrial Users according to OAC 3745-3-01(FF) must be notified of applicable pretreatment standards and requirements within 30 days of making such a determination. This inventory shall be updated at a frequency to ensure proper identification and characterization of industrial users.

3. Slug Load Control Plans for Significant Industrial Users

The permittee shall evaluate the need for a plan, device or structure to control a potential slug discharge at least once during the term of each significant industrial user's control mechanism. Existing significant industrial users shall be evaluated within one year of the effective date of this permit if the users have never been evaluated. New industrial users identified as significant industrial users shall be evaluated within one year of being identified as a significant industrial user.

4. Local Limits

The permittee shall develop and enforce technically based local limits to prevent the introduction of pollutants into the POTW which will interfere with the operation of the POTW, pass through the treatment works, be incompatible with the treatment works, or limit wastewater or sludge use options.

The permittee shall use the following waste load allocation values when evaluating local limits for the following pollutants for which a final effluent limit has not been established:

Arsenic	611 ug/l
Cadmium	26 ug/l
Chromium, hexavalent	31 ug/l
Chromium, total	785 ug/l
Copper	88 ug/l
Cyanide	49 ug/l
Lead	122 ug/l
Molybdenum	81499 ug/l
Nickel	611 ug/l
Selenium	20 ug/l
Zinc	670 ug/l

For the purpose of periodically reevaluating local limits, the permittee shall implement and maintain a sampling program to characterize pollutant contribution to the POTW from industrial and residential sources, including septage, and to determine pollutant removal efficiencies through the POTW. The permittee shall continue to review and develop local limits as necessary.

5. Control Mechanisms

The permittee shall issue control mechanisms to all industries determined to be Significant Industrial Users as define in OAC 3745-3-01(FF). Control mechanisms must meet at least the minimum requirements of OAC-3745-3-03(C)(1)(c).

6. Industrial Compliance Monitoring

The permittee shall sample and inspect industrial users in accordance with the approved program or approved modifications, including inspection and sampling of all significant industrial users at least annually. Sample collection, preservation and analysis must be performed in accordance with procedures in 40 CFR 136 and with sufficient care to produce evidence admissible in judicial enforcement proceedings.

The permittee shall also require, receive, and review self-monitoring and other industrial user reports when necessary to determine compliance with pretreatment standards and requirements. If the permittee performs sampling and analysis in lieu of an industrial user's self-monitoring, the permittee shall perform repeat sampling and analysis within 30 days of becoming aware of a permit violation, unless the permittee notifies the user of the violation and requires the user to perform the repeat analysis and reporting.

7. POTW Priority Pollutant Monitoring

The permittee shall annually monitor priority pollutants, as defined by U.S. EPA, in the POTW's influent, effluent and sludge. Sample collection, preservation, and analysis shall be performed using U.S. EPA approved methods.

a. A sample of the influent and the effluent shall be collected when industrial discharges are occurring at normal to maximum levels. Sampling of the influent shall be done prior to any recycle streams and sampling of the effluent shall be after disinfection. Both samples shall be collected on the same day or, alternately, the effluent sample may be collected following the influent sample by approximately the retention time of the POTW.

Sampling of sludge shall be representative of sludge removed to final disposal. A minimum of one grab sample shall be taken during actual sludge removal and disposal unless the POTW uses more than one disposal option. If multiple disposal options are used, the POTW shall collect a composite of grab samples from all disposal practices which are proportional to the annual flows to each type of disposal.

b. A reasonable attempt shall be made to identify and quantify additional constituents (excluding priority pollutants and unsubstituted aliphatic compounds) at each sample location. Identification of additional peaks more than ten times higher than the adjacent background noise on the total ion plots (reconstructed gas chromatograms) shall be attempted through the use of U.S. EPA/NIH computerized library of mass spectra, with visual confirmation by an experienced analyst. Quantification may be based on an order of magnitude estimate compared with an internal standard.

The results of these samples must be submitted on Ohio EPA Form 4221 with the permittee's annual pretreatment report. Samples may be collected at any time during the 12 months preceding the due date of the annual report and may be used to fulfill other NPDES monitoring requirements where applicable.

8. Enforcement

The permittee shall investigate all instances of noncompliance with pretreatment standards and requirements and take timely, appropriate, and effective enforcement action to resolve the noncompliance in accordance with the permittee's approved enforcement response plan.

On or prior to February 15th of each year, the permittee shall publish, in a newspaper of general circulation that provides meaningful public notice within the jurisdiction served by the permittee, a list of industrial users which, during the previous 12 months, have been in Significant Noncompliance [OAC 3745-3-03(C)(2)(h)] with applicable pretreatment standards or requirements.

9. Reporting

All reports required under this section shall be submitted to the following address in duplicate:

Ohio Environmental Protection Agency
Division of Surface Water
Pretreatment Unit
P.O. Box 1049
Columbus, OH 43216-1049

a. Quarterly Industrial User Violation Report

On or prior to the 1st day of February, May, August and November, the permittee shall report the industrial users that are in violation of applicable pretreatment standards during the corresponding quarterly periods of October through December, January through March, April through June and July through September. The report shall be prepared in accordance with guidance provided by Ohio EPA and shall include a description of all industrial user violations and corrective actions taken to resolve the violations.

b. Annual Pretreatment Report

On or prior to March 1st of each year the permittee shall submit a report on the effectiveness of the pretreatment program for the previous twelve-month period of January 1st through December 31st. The report shall be prepared in accordance with guidance provided by Ohio EPA and shall include, but not be limited to: a discussion of program effectiveness; and industrial user inventory; a description of the permittee's monitoring program; a description of any pass through or interference incidents; a copy of the annual publication of industries in Significant Noncompliance; priority pollutant monitoring results; a summary of septage volume and loading received in the past year; a summary of efforts to minimize pollutant loadings to CSOs from industrial users; and a list of agreements in place with industrial users as part of the city's control strategy for minimizing industrial user pollutant loadings on CSOs.

10. Record Keeping

All records of pretreatment activities including, but not limited to, industrial inventory data, monitoring results, enforcement actions, and reports submitted by industrial users must be maintained for a minimum of three (3) years. This period of retention shall be extended during the course of any unresolved litigation. Records must be made available to Ohio EPA and U.S. EPA upon request.

11. Program Modifications

Any proposed modifications of the approved pretreatment program must be submitted to Ohio EPA for review, on forms available from Ohio EPA and consistent with guidance provided by Ohio EPA. If the modification is deemed to be substantial, prior approval must be obtained before implementation; otherwise, the modification is considered to be effective 45 days after the date of application. Substantial program modifications include, among other things, changes to the POTW's legal authority, industrial user control mechanisms, local limits, confidentiality procedures, or monitoring frequencies.

CC. Outfall Signage

Not later than 4 months from the effective date of this permit, the permittee shall post a permanent marker on the stream bank at each outfall that is regulated under this NPDES permit where a marker does not currently exist. This includes final outfalls, bypasses, and combined sewer overflows. The marker shall consist at a minimum of the name of the establishment to which the permit was issued, the Ohio EPA permit number, and the outfall number and a contact telephone number. The information shall be printed in letters not less than two inches in height. The marker shall be a minimum of 2 feet by 2 feet and shall be a minimum of 3 feet above ground level. The sign shall not be obstructed such that persons in boats or persons swimming on the river or someone fishing or walking along the shore cannot read the sign. Vegetation shall be periodically removed to keep the sign visible. If the outfall is normally submerged the sign shall indicate that. If the outfall is a combined sewer outfall, the sign shall indicate that untreated human sewage may be discharged from the outfall during wet weather and that harmful bacteria may be present in the water. When an existing marker is replaced or reset, the new marker shall comply with the requirements of this section.

DD. Biomonitoring Program Requirements

As soon as possible but not later than three months after the effective date of this permit, the entity shall initiate an effluent biomonitoring program to determine the toxicity of the effluent from outfall 1PE00007001.

General Requirements

All toxicity testing conducted as required by this permit shall be done in accordance with "Reporting and Testing Guidance for Biomonitoring Required by the Ohio Environmental Protection Agency" (hereinafter, the "biomonitoring guidance"), Ohio EPA, July 1998 (or current revision). The Standard Operating Procedures (SOP) or verification of SOP submittal, as described in Section 1.B. of the biomonitoring guidance shall be submitted no later than three months after the effective date of this permit. If the laboratory performing the testing has modified its protocols, a new SOP is required.

Testing Requirements

1. Chronic Bioassays

For the life of this permit, the permittee shall conduct annual chronic toxicity tests using *Ceriodaphnia dubia* and fathead minnows (*Pimephales promelas*) on effluent samples from outfall 1PE00007001. These tests shall be conducted as specified in Section 3 of the biomonitoring guidance.

2. Acute Bioassays

Acute endpoints, as described in Section 2.H. of the biomonitoring guidance, shall be derived from the chronic test.

3. Testing of Ambient Water

In conjunction with the chronic toxicity tests, upstream control water shall be collected at a point outside the zone of effluent and receiving water interaction at station 1PE00007800. Testing of ambient waters shall be done in accordance with Section 3 of the biomonitoring guidance.

4. Data Review

a. Reporting

Following completion of each annual bioassay requirement, the permittee shall report results of the tests in accordance with Sections 3.H.1. and 3.H.2.a. of the biomonitoring guidance, including reporting the results on the monthly DMR and submitting a copy of the complete test report to Ohio EPA, Division of Surface Water, NPDES Permit Unit, P.O. Box 1049, Columbus, OH, 43216-1049.

Based on Ohio EPA's evaluation of the results, this permit may be modified to require additional biomonitoring, require a toxicity reduction evaluation, and/or contain whole effluent toxicity limits.

b. Definitions

TU_a = Acute Toxicity Units = 100/LC₅₀

TU_c = Chronic Toxicity Units = 100/IC₂₅

This equation for chronic toxicity units applies outside the mixing zone for warmwater, modified warmwater, exceptional warmwater, coldwater, and seasonal salmonid use designations except when the following equation is more restrictive (*Ceriodaphnia dubia* only):

TU_c = Chronic Toxic Units = 100/square root of (NOEC x LOEC)

EE. Upon completion of the Phase One No Feasible Alternatives Analysis plan, the permittee will submit a summary report that details operating conditions necessary to provide complete secondary treatment to flows up to 40 MGD. This report will be submitted no later than November 1, 2013 (Schedule of Compliance, Item C.5.a). Upon written acceptance of this report by Ohio EPA, the City shall begin providing complete secondary treatment to flows up to 40 MGD. Bypassed flows above 40 MGD shall be treated and monitored in accordance with the requirements for outfall 1PE00007067.

FF. Ohio EPA acknowledges that some violations of permit limits may occur during times when the permittee is stress testing the treatment plant to determine the limits of wet weather operation. This testing is part of the permittee's No Feasible Alternatives analysis. The permittee shall notify the Southwest District Office prior to initiation of tests that have a reasonable potential to result in effluent limit violations. The permittee should provide the Agency with a brief written summary of test activities and results within one week of completing a test that will result in permit violations.

PART III - GENERAL CONDITIONS

1. DEFINITIONS

"Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

"Average weekly" discharge limitation means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week. Each of the following 7-day periods is defined as a calendar week: Week 1 is Days 1 - 7 of the month; Week 2 is Days 8 - 14; Week 3 is Days 15 - 21; and Week 4 is Days 22 - 28. If the "daily discharge" on days 29, 30 or 31 exceeds the "average weekly" discharge limitation, Ohio EPA may elect to evaluate the last 7 days of the month as Week 4 instead of Days 22 - 28. Compliance with fecal coliform bacteria or E coli bacteria limitations shall be determined using the geometric mean.

"Average monthly" discharge limitation means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month. Compliance with fecal coliform bacteria or E coli bacteria limitations shall be determined using the geometric mean.

"85 percent removal" means the arithmetic mean of the values for effluent samples collected in a period of 30 consecutive days shall not exceed 15 percent of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.

"Absolute Limitations" Compliance with limitations having descriptions of "shall not be less than," "not greater than," "shall not exceed," "minimum," or "maximum" shall be determined from any single value for effluent samples and/or measurements collected.

"Net concentration" shall mean the difference between the concentration of a given substance in a sample taken of the discharge and the concentration of the same substances in a sample taken at the intake which supplies water to the given process. For the purpose of this definition, samples that are taken to determine the net concentration shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"Net Load" shall mean the difference between the load of a given substance as calculated from a sample taken of the discharge and the load of the same substance in a sample taken at the intake which supplies water to given process. For purposes of this definition, samples that are taken to determine the net loading shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"MGD" means million gallons per day.

"mg/l" means milligrams per liter.

"ug/l" means micrograms per liter.

"ng/l" means nanograms per liter.

"S.U." means standard pH unit.

"kg/day" means kilograms per day.

"Reporting Code" is a five digit number used by the Ohio EPA in processing reported data. The reporting code does not imply the type of analysis used nor the sampling techniques employed.

"Quarterly (1/Quarter) sampling frequency" means the sampling shall be done in the months of March, June, August, and December, unless specifically identified otherwise in the Effluent Limitations and Monitoring Requirements table.

"Yearly (1/Year) sampling frequency" means the sampling shall be done in the month of September, unless specifically identified otherwise in the effluent limitations and monitoring requirements table.

"Semi-annual (2/Year) sampling frequency" means the sampling shall be done during the months of June and December, unless specifically identified otherwise.

"Winter" shall be considered to be the period from November 1 through April 30.

"Bypass" means the intentional diversion of waste streams from any portion of the treatment facility.

"Summer" shall be considered to be the period from May 1 through October 31.

"Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

"Sewage sludge" means a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works as defined in section 6111.01 of the Revised Code. "Sewage sludge" includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes. "Sewage sludge" does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator, grit and screenings generated during preliminary treatment of domestic sewage in a treatment works, animal manure, residue generated during treatment of animal manure, or domestic septage.

"Sewage sludge weight" means the weight of sewage sludge, in dry U.S. tons, including admixtures such as liming materials or bulking agents. Monitoring frequencies for sewage sludge parameters are based on the reported sludge weight generated in a calendar year (use the most recent calendar year data when the NPDES permit is up for renewal).

"Sewage sludge fee weight" means the weight of sewage sludge, in dry U.S. tons, excluding admixtures such as liming materials or bulking agents. Annual sewage sludge fees, as per section 3745.11(Y) of the Ohio Revised Code, are based on the reported sludge fee weight for the most recent calendar year.

2. GENERAL EFFLUENT LIMITATIONS

The effluent shall, at all times, be free of substances:

- A. In amounts that will settle to form putrescent, or otherwise objectionable, sludge deposits; or that will adversely affect aquatic life or water fowl;
- B. Of an oily, greasy, or surface-active nature, and of other floating debris, in amounts that will form noticeable accumulations of scum, foam or sheen;
- C. In amounts that will alter the natural color or odor of the receiving water to such degree as to create a nuisance;
- D. In amounts that either singly or in combination with other substances are toxic to human, animal, or aquatic life;
- E. In amounts that are conducive to the growth of aquatic weeds or algae to the extent that such growths become inimical to more desirable forms of aquatic life, or create conditions that are unsightly, or constitute a nuisance in any other fashion;
- F. In amounts that will impair designated instream or downstream water uses.

3. FACILITY OPERATION AND QUALITY CONTROL

All wastewater treatment works shall be operated in a manner consistent with the following:

- A. At all times, the permittee shall maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee necessary to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with conditions of the permit.
- B. The permittee shall effectively monitor the operation and efficiency of treatment and control facilities and the quantity and quality of the treated discharge.
- C. Maintenance of wastewater treatment works that results in degradation of effluent quality shall be scheduled during non-critical water quality periods and shall be carried out in a manner approved by Ohio EPA as specified in the Paragraph in the PART III entitled, "UNAUTHORIZED DISCHARGES".

4. REPORTING

A. Monitoring data required by this permit shall be submitted monthly on Ohio EPA 4500 Discharge Monitoring Report (DMR) forms using the electronic DMR (e-DMR) internet application. e-DMR allows permitted facilities to enter, sign, and submit DMRs on the internet. e-DMR information is found on the following web page:

<http://www.epa.ohio.gov/dsw/edmr/eDMR.aspx>

Alternatively, if you are unable to use e-DMR due to a demonstrated hardship, monitoring data may be submitted on paper DMR forms provided by Ohio EPA. Monitoring data shall be typed on the forms. Please contact Ohio EPA, Division of Surface Water at (614) 644-2050 if you wish to receive paper DMR forms.

B. DMRs shall be signed by a facility's Responsible Official or a Delegated Responsible Official (i.e. a person delegated by the Responsible Official). The Responsible Official of a facility is defined as:

1. For corporations - a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation; or the manager of one or more manufacturing, production or operating facilities, provided the manager is authorized to make management decisions which govern the operation of the regulated facility including having explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures;
2. For partnerships - a general partner;
3. For a sole proprietorship - the proprietor; or,
4. For a municipality, state or other public facility - a principal executive officer, a ranking elected official or other duly authorized employee.

For e-DMR, the person signing and submitting the DMR will need to obtain an eBusiness Center account and Personal Identification Number (PIN). Additionally, Delegated Responsible Officials must be delegated by the Responsible Official, either on-line using the eBusiness Center's delegation function, or on a paper delegation form provided by Ohio EPA. For more information on the PIN and delegation processes, please view the following web page:

<http://epa.ohio.gov/dsw/edmr/eDMR.aspx>

C. DMRs submitted using e-DMR shall be submitted to Ohio EPA by the 20th day of the month following the month-of-interest. DMRs submitted on paper must include the original signed DMR form and shall be mailed to Ohio EPA at the following address so that they are received no later than the 15th day of the month following the month-of-interest:

Ohio Environmental Protection Agency
Lazarus Government Center
Division of Surface Water - PCU
P.O. Box 1049
Columbus, Ohio 43216-1049

D. Regardless of the submission method, a paper copy of the submitted Ohio EPA 4500 DMR shall be maintained onsite for records retention purposes (see Section 7. RECORDS RETENTION). For e-DMR users, view and print the DMR from the Submission Report Information page after each original or revised DMR is submitted. For submittals on paper, make a copy of the completed paper form after it is signed by a Responsible Official or a Delegated Responsible Official.

E. If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified in Section 5. SAMPLING AND ANALYTICAL METHODS, the results of such monitoring shall be included in the calculation and reporting of the values required in the reports specified above.

F. Analyses of pollutants not required by this permit, except as noted in the preceding paragraph, shall not be reported to the Ohio EPA, but records shall be retained as specified in Section 7. RECORDS RETENTION.

5. SAMPLING AND ANALYTICAL METHOD

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored flow. Test procedures for the analysis of pollutants shall conform to regulation 40 CFR 136, "Test Procedures For The Analysis of Pollutants" unless other test procedures have been specified in this permit. The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to insure accuracy of measurements.

6. RECORDING OF RESULTS

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- A. The exact place and date of sampling; (time of sampling not required on EPA 4500)
- B. The person(s) who performed the sampling or measurements;
- C. The date the analyses were performed on those samples;
- D. The person(s) who performed the analyses;
- E. The analytical techniques or methods used; and
- F. The results of all analyses and measurements.

7. RECORDS RETENTION

The permittee shall retain all of the following records for the wastewater treatment works for a minimum of three years except those records that pertain to sewage sludge disposal, use, storage, or treatment, which shall be kept for a minimum of five years, including:

- A. All sampling and analytical records (including internal sampling data not reported);
- B. All original recordings for any continuous monitoring instrumentation;
- C. All instrumentation, calibration and maintenance records;
- D. All plant operation and maintenance records;
- E. All reports required by this permit; and
- F. Records of all data used to complete the application for this permit for a period of at least three years, or five years for sewage sludge, from the date of the sample, measurement, report, or application.

These periods will be extended during the course of any unresolved litigation, or when requested by the Regional Administrator or the Ohio EPA. The three year period, or five year period for sewage sludge, for retention of records shall start from the date of sample, measurement, report, or application.

8. AVAILABILITY OF REPORTS

Except for data determined by the Ohio EPA to be entitled to confidential status, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the appropriate district offices of the Ohio EPA. Both the Clean Water Act and Section 6111.05 Ohio Revised Code state that effluent data and receiving water quality data shall not be considered confidential.

9. DUTY TO PROVIDE INFORMATION

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking, and reissuing, or terminating the permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

10. RIGHT OF ENTRY

The permittee shall allow the Director or an authorized representative upon presentation of credentials and other documents as may be required by law to:

- A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit.
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
- D. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

11. UNAUTHORIZED DISCHARGES

A. Bypass Not Exceeding Limitations - The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 11.B and 11.C.

B. Notice

1. Anticipated Bypass - If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

2. Unanticipated Bypass - The permittee shall submit notice of an unanticipated bypass as required in paragraph 12.B (24 hour notice).

C. Prohibition of Bypass

1. Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:

- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
- c. The permittee submitted notices as required under paragraph 11.B.

2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 11.C.1.

12. NONCOMPLIANCE NOTIFICATION

A. Exceedance of a Daily Maximum Discharge Limit

1. The permittee shall report noncompliance that is the result of any violation of a daily maximum discharge limit for any of the pollutants listed by the Director in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.state.oh.us
Southwest District Office: swdo24hournpdes@epa.state.oh.us
Northwest District Office: nwdo24hournpdes@epa.state.oh.us
Northeast District Office: nedo24hournpdes@epa.state.oh.us
Central District Office: cdo24hournpdes@epa.state.oh.us
Central Office: co24hournpdes@epa.state.oh.us

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site under the Monitoring and Reporting - Non-Compliance Notification section:

<http://epa.ohio.gov/dsw/permits/individuals.aspx>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330
Southwest District Office: (800) 686-8930
Northwest District Office: (800) 686-6930
Northeast District Office: (800) 686-6330
Central District Office: (800) 686-2330
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
- b. The limit(s) that has been exceeded;
- c. The extent of the exceedance(s);
- d. The cause of the exceedance(s);
- e. The period of the exceedance(s) including exact dates and times;
- f. If uncorrected, the anticipated time the exceedance(s) is expected to continue; and,
- g. Steps taken to reduce, eliminate or prevent occurrence of the exceedance(s).

B. Other Permit Violations

1. The permittee shall report noncompliance that is the result of any unanticipated bypass resulting in an exceedance of any effluent limit in the permit or any upset resulting in an exceedance of any effluent limit in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.state.oh.us
Southwest District Office: swdo24hournpdes@epa.state.oh.us
Northwest District Office: nwdo24hournpdes@epa.state.oh.us
Northeast District Office: nedo24hournpdes@epa.state.oh.us
Central District Office: cdo24hournpdes@epa.state.oh.us
Central Office: co24hournpdes@epa.state.oh.us

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site:

<http://www.epa.ohio.gov/dsw/permits/permits.aspx>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330
Southwest District Office: (800) 686-8930
Northwest District Office: (800) 686-6930
Northeast District Office: (800) 686-6330
Central District Office: (800) 686-2330
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
 - b. The time(s) at which the discharge occurred, and was discovered;
 - c. The approximate amount and the characteristics of the discharge;
 - d. The stream(s) affected by the discharge;
 - e. The circumstances which created the discharge;
 - f. The name and telephone number of the person(s) who have knowledge of these circumstances;
 - g. What remedial steps are being taken; and,
 - h. The name and telephone number of the person(s) responsible for such remedial steps.
2. The permittee shall report noncompliance that is the result of any spill or discharge which may endanger human health or the environment within thirty (30) minutes of discovery by calling the 24-Hour Emergency Hotline toll-free at (800) 282-9378. The permittee shall also report the spill or discharge by e-mail or telephone within twenty-four (24) hours of discovery in accordance with B.1 above.
- C. When the telephone option is used for the noncompliance reports required by A and B, the permittee shall submit to the appropriate Ohio EPA district office a confirmation letter and a completed noncompliance report within five (5) days of the discovery of the noncompliance. This follow up report is not necessary for the e-mail option which already includes a completed noncompliance report.
- D. If the permittee is unable to meet any date for achieving an event, as specified in a schedule of compliance in their permit, the permittee shall submit a written report to the appropriate Ohio EPA district office within fourteen (14) days of becoming aware of such a situation. The report shall include the following:
1. The compliance event which has been or will be violated;
 2. The cause of the violation;
 3. The remedial action being taken;
 4. The probable date by which compliance will occur; and,
 5. The probability of complying with subsequent and final events as scheduled.
- E. The permittee shall report all other instances of permit noncompliance not reported under paragraphs A or B of this section on their monthly DMR submission. The DMR shall contain comments that include the information listed in paragraphs A or B as appropriate.
- F. If the permittee becomes aware that it failed to submit an application, or submitted incorrect information in an application or in any report to the director, it shall promptly submit such facts or information.

13. RESERVED

14. DUTY TO MITIGATE

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

15. AUTHORIZED DISCHARGES

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than, or at a level in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit. Such violations may result in the imposition of civil and/or criminal penalties as provided for in Section 309 of the Act and Ohio Revised Code Sections 6111.09 and 6111.99.

16. DISCHARGE CHANGES

The following changes must be reported to the appropriate Ohio EPA district office as soon as practicable:

A. For all treatment works, any significant change in character of the discharge which the permittee knows or has reason to believe has occurred or will occur which would constitute cause for modification or revocation and reissuance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. Notification of permit changes or anticipated noncompliance does not stay any permit condition.

B. For publicly owned treatment works:

1. Any proposed plant modification, addition, and/or expansion that will change the capacity or efficiency of the plant;
2. The addition of any new significant industrial discharge; and
3. Changes in the quantity or quality of the wastes from existing tributary industrial discharges which will result in significant new or increased discharges of pollutants.

C. For non-publicly owned treatment works, any proposed facility expansions, production increases, or process modifications, which will result in new, different, or increased discharges of pollutants.

Following this notice, modifications to the permit may be made to reflect any necessary changes in permit conditions, including any necessary effluent limitations for any pollutants not identified and limited herein. A determination will also be made as to whether a National Environmental Policy Act (NEPA) review will be required. Sections 6111.44 and 6111.45, Ohio Revised Code, require that plans for treatment works or improvements to such works be approved by the Director of the Ohio EPA prior to initiation of construction.

D. In addition to the reporting requirements under 40 CFR 122.41(l) and per 40 CFR 122.42(a), all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:

1. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit. If that discharge will exceed the highest of the "notification levels" specified in 40 CFR Sections 122.42(a)(1)(i) through 122.42(a)(1)(iv).
2. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" specified in 122.42(a)(2)(i) through 122.42(a)(2)(iv).

17. TOXIC POLLUTANTS

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement. Following establishment of such standards or prohibitions, the Director shall modify this permit and so notify the permittee.

18. PERMIT MODIFICATION OR REVOCATION

A. After notice and opportunity for a hearing, this permit may be modified or revoked, by the Ohio EPA, in whole or in part during its term for cause including, but not limited to, the following:

1. Violation of any terms or conditions of this permit;
2. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
3. Change in any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge.

B. Pursuant to rule 3745-33-04, Ohio Administrative Code, the permittee may at any time apply to the Ohio EPA for modification of any part of this permit. The filing of a request by the permittee for a permit modification or revocation does not stay any permit condition. The application for modification should be received by the appropriate Ohio EPA district office at least ninety days before the date on which it is desired that the modification become effective. The application shall be made only on forms approved by the Ohio EPA.

19. TRANSFER OF OWNERSHIP OR CONTROL

This permit may be transferred or assigned and a new owner or successor can be authorized to discharge from this facility, provided the following requirements are met:

A. The permittee shall notify the succeeding owner or successor of the existence of this permit by a letter, a copy of which shall be forwarded to the appropriate Ohio EPA district office. The copy of that letter will serve as the permittee's notice to the Director of the proposed transfer. The copy of that letter shall be received by the appropriate Ohio EPA district office sixty (60) days prior to the proposed date of transfer;

B. A written agreement containing a specific date for transfer of permit responsibility and coverage between the current and new permittee (including acknowledgement that the existing permittee is liable for violations up to that date, and that the new permittee is liable for violations from that date on) shall be submitted to the appropriate Ohio EPA district office within sixty days after receipt by the district office of the copy of the letter from the permittee to the succeeding owner;

At anytime during the sixty (60) day period between notification of the proposed transfer and the effective date of the transfer, the Director may prevent the transfer if he concludes that such transfer will jeopardize compliance with the terms and conditions of the permit. If the Director does not prevent transfer, he will modify the permit to reflect the new owner.

20. OIL AND HAZARDOUS SUBSTANCE LIABILITY

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

21. SOLIDS DISPOSAL

Collected grit and screenings, and other solids other than sewage sludge, shall be disposed of in such a manner as to prevent entry of those wastes into waters of the state, and in accordance with all applicable laws and rules.

22. CONSTRUCTION AFFECTING NAVIGABLE WATERS

This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

23. CIVIL AND CRIMINAL LIABILITY

Except as exempted in the permit conditions on UNAUTHORIZED DISCHARGES or UPSETS, nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

24. STATE LAWS AND REGULATIONS

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Clean Water Act.

25. PROPERTY RIGHTS

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations.

26. UPSET

The provisions of 40 CFR Section 122.41(n), relating to "Upset," are specifically incorporated herein by reference in their entirety. For definition of "upset," see Part III, Paragraph 1, DEFINITIONS.

27. SEVERABILITY

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

28. SIGNATORY REQUIREMENTS

All applications submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR 122.22.

All reports submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR Section 122.22.

29. OTHER INFORMATION

A. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

B. ORC 6111.99 provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

C. ORC 6111.99 states that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

D. ORC 6111.99 provides that any person who violates Sections 6111.04, 6111.042, 6111.05, or division (A) of Section 6111.07 of the Revised Code shall be fined not more than \$25,000 or imprisoned not more than one year, or both.

30. NEED TO HALT OR REDUCE ACTIVITY

40 CFR 122.41(c) states that it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with conditions of this permit.

31. APPLICABLE FEDERAL RULES

All references to 40 CFR in this permit mean the version of 40 CFR which is effective as of the effective date of this permit.

32. AVAILABILITY OF PUBLIC SEWERS

Notwithstanding the issuance or non-issuance of an NPDES permit to a semi-public disposal system, whenever the sewage system of a publicly owned treatment works becomes available and accessible, the permittee operating any semi-public disposal system shall abandon the semi-public disposal system and connect it into the publicly owned treatment works.