

City Manager's Journal

Re: Index of Restricted Substances

Date: July 18, 2019

According the Codified Ordinance 916.02 (5), the attached Index of Restricted Substances shall be posted at the Wastewater Treatment Plant, City Service Center and on the City's website. Any changes to this index shall be noted in the City Manager's Journal and posted at the above designated locations.



Bryan Heck, City Manager

Index of Restricted Substances

Per 916.02(5) of the City of Springfield Codified Ordinances, no person shall discharge or cause to be discharged to any public sewers any waters or wastes containing objectionable or toxic substances in excess of the following allowable limits determined by the Director and listed in the “Index of Restricted Substances” posted at the Wastewater Treatment Plant, the City Service Center, and on the City’s website.

Effluent Characteristics	Discharge Limitations
Total Arsenic	0.050 mg/L
Total Cadmium	0.050 mg/L
Total Chromium	2.400 mg/L
Total Copper	0.900 mg/L
Total Lead	0.250 mg/L
Total Mercury	0.0015 mg/L
Total Nickel	0.730 mg/L
Total Silver	0.100 mg/L
Total Zinc	1.900 mg/L
Total Cyanide	2.30 mg/L
Total Toxic Organics	2.13 mg/L